

Message Text

LIMITED OFFICIAL USE

PAGE 01 WELLIN 02792 270523Z

11
ACTION SY-05

INFO OCT-01 EA-07 ISO-00 FBO-02 /015 W
----- 026594

R 270435Z JUL 76
FM AMEMBASSY WELLINGTON
TO SECSTATE WASHDC 1729
INFO AMEMBASSY CANBERRA
AMCONSUL HONG KONG

LIMITED OFFICIAL USE WELLINGTON 2792

DEPT FOR A/SY/FO; CANBERRA FOR TSO; HONG KONG FOR RSS/TRC

E.O. 11652: N/A
TAGS: ASEC, ABLD
SUBJ: CONSTRUCTION NEW OB, PROPERTY 12313-A, SECURITY REQUIREMENTS

REF: CONTRACT DRAWING A-7

1. AFTER A REVIEW OF PLANS FOR THE NEW CHANCERY WITH THE FBO PROJECT SUPERVISOR, IT IS THE RECOMMENDATION OF THE RSO THAT THE INTERIOR PARTITIONING BETWEEN ROOMS 203 AND 204/228 AND 201 BE FORTIFIED WITH 1/4 INCH BULLET-RESISTANT ALUMINUM ARMOR. IT IS ESTIMATED THAT IT WILL TAKE 300 SQUARE FEET OF ARMORING MATERIAL TO COMPLETE THE JOB.

2. RSO WELLINGTON ALSO RECOMMENDS INSTALLATION OF BULLET RESISTANT TRANSPARENT ARMOR FOR AMBASSADOR'S AND DCM'S OFFICE WINDOWS. RSO SUGGESTS 1 1/4 INCH LEXGARD WITH 1/4 INCH SAFETYGLASS ON IMPACT SIDE.

3. IT IS RECOMMENDED THAT MATERIALS BE GOVERNMENT FURNISHED AND CONTRACTOR INSTALL. FPO PROJECT SUPERVISOR, UPON ADVICE FROM A/FBO, WILL GET PROPOSED CHANGE ORDER FROM CONTRACTOR. IT SHOULD BE NOTED THAT IF CONTRACTOR IS TO INSTALL BULLET-RESISTANT ARMOR (PARA 1) IT SHOULD BE COMPLETED PRIOR TO ERECTION OF ACR. BY ACTING NOW WE CAN ACHIEVE COST SAVING AND TIMELY INSTALLATION.

LIMITED OFFICIAL USE

LIMITED OFFICIAL USE

PAGE 02 WELLIN 02792 270523Z

4. THE ABOVE RECOMMENDATIONS HAVE THE FULL ENDORSEMENT OF THE
AMBASSADOR AND ADMINISTRATIVE OFFICER.
SELDEN

LIMITED OFFICIAL USE

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 JAN 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 27 JUL 1976
Decaption Date: 01 JAN 1960
Decaption Note:
Disposition Action: RELEASED
Disposition Approved on Date:
Disposition Authority: BoyleJA
Disposition Case Number: n/a
Disposition Comment: 25 YEAR REVIEW
Disposition Date: 28 MAY 2004
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1976WELLIN02792
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: N/A
Errors: N/A
Film Number: D760288-0770
From: WELLINGTON
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1976/newtext/t19760715/aaaaannl.tel
Line Count: 64
Locator: TEXT ON-LINE, ON MICROFILM
Office: ACTION SY
Original Classification: LIMITED OFFICIAL USE
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 2
Previous Channel Indicators: n/a
Previous Classification: LIMITED OFFICIAL USE
Previous Handling Restrictions: n/a
Reference: n/a
Review Action: RELEASED, APPROVED
Review Authority: BoyleJA
Review Comment: n/a
Review Content Flags:
Review Date: 21 MAY 2004
Review Event:
Review Exemptions: n/a
Review History: RELEASED <21 MAY 2004 by ifshinsr>; APPROVED <15 SEP 2004 by BoyleJA>
Review Markings:

Margaret P. Grafeld
Declassified/Released
US Department of State
EO Systematic Review
04 MAY 2006

Review Media Identifier:
Review Referrals: n/a
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
Secure: OPEN
Status: NATIVE
Subject: CONSTRUCTION NEW OB, PROPERTY 12313-A, SECURITY REQUIREMENTS
TAGS: ASEC, ABLD
To: STATE
Type: TE
Markings: Margaret P. Grafeld Declassified/Released US Department of State EO Systematic Review 04 MAY 2006